KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00422	**OWNER'S NAME:**	ROMANS
DATE:	4/25/2017	**TYPE:**	Insulation and mechanic
TIME STARTED:	10:46 AM	**INSPECTOR:**	Jessica Contratto
MAP NUMBER:	20-15-29050-0217		

1. Insulation ok
2. Walls foam flash and batt
3. Vault insulation ok. R-38 batt
4. Remove plastic masking from master bed fireplace chimney

INSTRUCTIONS: Ok to cover when batts are completed

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jessica.contratto **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506