KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00433	**OWNER'S NAME:**	WILDER
DATE:	9/14/2016	**TYPE:**	Foundation walls
TIME STARTED:	11:30 AM	**INSPECTOR:**	Jessica Contratto
MAP NUMBER:	19-16-17056-0039		

1. Seismic zone C requires one #4 bar at top of walls. Also extend vertical bars to top bar

INSTRUCTIONS: Complete above, re-inspect

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jessica.contratto **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506