KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

| | | | |
|---|---|---|---|
| **PERMIT NUMBER:** | BP-16-00468 | **OWNER'S NAME:** | MORTON |
| **DATE:** | 11/15/2016 | **TYPE:** | Mechanical and plumbir |
| **TIME STARTED:** | 2:50 PM | **INSPECTOR:** | Justin Bennett |
| **MAP NUMBER:** | 20-17-32055-0002 | | |

1. Supply @ 48# - needs to be a min of 50#/15 mins
2. DWV not on test

**INSTRUCTIONS:** Pressurize plumbing/Re-Inspection

**NEXT INSPECTION:** Re-Inspection

**RE-INSPECTION FEE DUE?** ☑ **NO** ☐ **YES** **$ _____**

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____justin.bennett **@co.kittitas.wa.us**

**INSPECTION REQUEST LINE: 509-962-7694**

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506