KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00478

OWNER'S NAME: HAWORTH

DATE: 12/7/2016

TYPE: Mechanical

TIME STARTED: 12:19 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 22-11-09050-0136

1. Bath fan will be whole house fan on timer
2. Range vent will be installed at final
3. Dryer vent ok
4. On demand water heater will be installed to meet 1.5 energy credits required
5. Gas line not run yet for wall unit and water heater
6. Framing also performed
7. Stairs not required to be compliant- total loft area is under 200 s.f. where >5' height
8. Framing ok

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: Insulation/gas line

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jessica.contratto **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506