



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00482

OWNER'S NAME: SCHUFREIDER

DATE: 5/1/2017

TYPE: Floor framing

TIME STARTED: 2:50 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-19053-0001

1. Slip sheets needed under hangers when in contact with PT - in progress

INSTRUCTIONS: Complete above/Once complete Ok to cover

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506