



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00583

OWNER'S NAME: STORER

DATE: 9/23/2016

TYPE: Final

TIME STARTED: 12:02 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-06057-0003

1. Gas piping @ 0# - Needs to be 15#/15 mins

INSTRUCTIONS: Pressurize gas line to 15#/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506