



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00584

OWNER'S NAME: KIDWELL

DATE: 2/15/2017

TYPE: Mechanical and plumbir

TIME STARTED: 3:04 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0028

1. Mechanical Supply/Return OK.
2. Mechanical Exhaust OK.
3. Fireplace Rough In OK.
4. Plumbing Rough In OK. DWV at 5#/15min. OK. Supply at 50#/15min. OK.

INSTRUCTIONS: Complete L&I Electrical Inspection

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506