



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00605

OWNER'S NAME: ROSE

DATE: 12/1/2016

TYPE: Slab

TIME STARTED: 11:41 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-23-19010-0003

1. Upper slab rebar ok
2. Saw base footings need 4 inverted u-hoops at top per detail

INSTRUCTIONS: Hoops will be added before pour

NEXT INSPECTION: Lower slab and table footings

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506