



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00625

OWNER'S NAME: BARANOWSKI

DATE: 2/24/2017

TYPE: Exterior shear

TIME STARTED: 12:11 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0088

1. Exterior Shear Ok
2. HD's not installed at time of inspection
3. CS strapping in trash room not nailed
4. Tighten up nailing on interior shear (throughout)
5. HD needed @ Garage man door (strap layout off)

INSTRUCTIONS: Complete above/Verify HD's and Interior Shear @ Framing/Ok to cover exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506