



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00628

OWNER'S NAME: DK PROFESSIONAL

DATE: 5/24/2017

TYPE: Shearwalls

TIME STARTED: 11:06 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12068-0004

1. Tighten up W6 in (3) locations @ horiz. seam - red crayon
2. HD's Ok

INSTRUCTIONS: Complete above/Once complete Ok to cover

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506