



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00628

OWNER'S NAME: DK PROFESSIONAL

DATE: 6/21/2017

TYPE: Insulation

TIME STARTED: 3:40 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12068-0004

1. Wall Insulation - Batt
2. Floor Insulation - Batt
3. Rafter Insulation - Batt w/ vapor barrier
4. NOTE: Contractor to use approved PVA Primer - Verify @ Final
5. FSK paper installed @ fireplace

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506