



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00641

OWNER'S NAME: KITTITAS CO

DATE: 3/2/2017

TYPE: Gas piping

TIME STARTED: 12:15 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-24050-0002

1. Underground Gas Piping Inspection OK. 15#/15min. OK. NOTE: Interior Not Tested.
2. NOTE: Photos Saved to 'T' Drive.
3. Replacement/RetroFit Interior Ductwork OK.
4. NOTE: Controls to Be Seen Later.

INSTRUCTIONS: OK to Backfill Exterior Trench. OK to Insulate Interior Ducts.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506