



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00642

OWNER'S NAME: ELLINGSWORTH

DATE: 10/27/2016

TYPE: Final

TIME STARTED: 11:19 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 22-11-15052-0009

1. Mechanical installation Ok
2. Final Ok
3. NOTE: Condensation accumulating under outdoor unit on deck - secondary condensate pan @ outdoor unit to be considered to avoid slick surface

INSTRUCTIONS: Final Ok

NEXT INSPECTION: N/A

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506