



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00672

OWNER'S NAME: TIREY

DATE: 12/22/2016

TYPE: Post holes

TIME STARTED: 11:54 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-33020-0033

1. Setbacks Ok
2. Post holes Ok
3. NOTE: Do not pour concrete if ground is frozen

INSTRUCTIONS: Ok to pour when ground is suitable

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506