



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00687

OWNER'S NAME: CARLSON

DATE: 12/6/2016

TYPE: Floor framing

TIME STARTED: 10:34 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0132

1. Complete underfloor shear
2. Complete solid blocking @ floor joists per plans
3. DO NOT COVER

INSTRUCTIONS: DO NOT COVER/Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506