



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00722

OWNER'S NAME: LOCKLEER

DATE: 6/27/2017

TYPE: Footings

TIME STARTED: 12:41 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-28000-0011

1. Setbacks OK.
2. Post Hole Depth OK.
3. Punch Pads Require Rebar. Rebar Not On Site. Rebar Must Be Inspected.

INSTRUCTIONS: DO NOT POUR. Install Rebar and Call for ReInspection.

NEXT INSPECTION: Post Holes

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506