



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00726

OWNER'S NAME: HERBIG

DATE: 7/17/2017

TYPE: Rough-in plumbing

TIME STARTED: 11:16 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-09056-0003

1. DWV on Stack - Ok
2. Supply @ 55#/15 mins - Ok
3. Plumbing RI Ok
4. NOTE: Verify stair width @ Framing

### INSTRUCTIONS:

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506