



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00768

OWNER'S NAME: BAKER

DATE: 12/7/2016

TYPE: Final

TIME STARTED: 3:37 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-34054-0006

1. Mini Split Heat Pump Install OK.
2. Final OK.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506