



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-17-00012

OWNER'S NAME: HOWARD

DATE: 3/20/2017

TYPE: Multiple (see notes)

TIME STARTED: 11:13 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-17050-0411

1. Trusses OK.
2. Framing OK.
3. WUIC Final From Fire Marshalls Office Not Completed. (Defensible Space Requirements Do Not Appear to Be Met.)
4. Final Not Approved.

**INSTRUCTIONS:** Schedule WUIC Final. Confirm Defensible Space Requirements are Complete Prior to Scheduling. Once Fire Marshall Approval Has Been Obtained Structure Can Be Finaled Administratively.

**NEXT INSPECTION:** WUIC Final

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506