KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-17-00018	**OWNER'S NAME:**	BUCH
DATE:	5/18/2017	**TYPE:**	Rough-in plumbing
TIME STARTED:	3:59 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	21-14-21050-0007		

1. NOTE: Owner Intended Slab Plumbing.
2. Slab Plummbig OK. DWV on Stack Test. OK.

INSTRUCTIONS: OK to Backfill.

NEXT INSPECTION: Slab Insulation

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jeremy.haberman **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506