



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-17-00048

OWNER'S NAME: HARWELL

DATE: 6/16/2017

TYPE: Final

TIME STARTED: 12:22 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-20-29050-0001

1. Air Handler installation Ok
2. Cooling Coil installation Ok
3. Condensing Unit installation Ok
4. Mechanical Final Ok

INSTRUCTIONS: Mech Final Ok

NEXT INSPECTION: N/A

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506