KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-17-00127	**OWNER'S NAME:**	PINNEY
DATE:	7/10/2017	**TYPE:**	Shearwalls
TIME STARTED:	9:10 AM	**INSPECTOR:**	Jessica Contratto
MAP NUMBER:	20-14-35052-0098		

1. Bottom edge nailing on 3 panels. Marked on plans n shear page
2. H20 at 140#-ok
3. Venting for kitchen sink is possible. Studor vent not allowed
4. Have engineer approval of post connection on site for verification

INSTRUCTIONS: Complete nailing, ok to cover exterior

NEXT INSPECTION: frame/mech/DWV

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jessica.contratto **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506