



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-14-00048 OWNER'S NAME: SINNETT
DATE: 8/26/2014 TYPE: Slab
TIME STARTED: 12:52 PM INSPECTOR: Amber Green
MAP NUMBER: 20-14-14050-0925

| | |
|--|-----------------------------------------------------------------------------------------------------------------------------------------|
| | 1. Thickened Slab Footings OK |
| | 2. DWV (stack/15min) - OK |
| | 3. There are no plumbing fixtures permitted in the basement. If fixtures are being added, additional plumbing permits will be required. |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: No framing may occur until the full permit has been issued. Ok to pour slab.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506