

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

| PERMIT NUMBER: | FO-14-00070 | OWNER'S NAME: | ELY |
|----------------|------------------|---------------|----------------------|
| DATE: | 9/12/2014 | TYPE: | Re-inspection |
| TIME STARTED: | 10:04 AM | INSPECTOR: | Amber Green |
| MAP NUMBER: | 20-15-29051-0075 | | |

| 1. None of the spread footing depths are per plan. | | |
|--|--|--|
| 2. Interior point load footing depth not per plan. | | |
| 3. Interior strip footing depth not per plan. | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

INSTRUCTIONS: Fix Above. Re-Fee. Re-Call Inspection.

] NO

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?

VES

\$ 65.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506