INSPECTION REPORT

OWNER'S NAME:

GROENKE

FO-14-00114

PERMIT NUMBER:

DATE:	10/21/2014	TYPE:	Footings
TIME STARTED:	2:20 PM	INSPECTOR:	Mike Flory
MAP NUMBER:	18-19-32063-0002	2	
1. ADD 26 x 26 LOAD PADS AT GARAGE DOOR LOCATIONS THEN OK TO POUR.			
2. WILL SEE PADS AT FOUNDATION WALL			
INSTRUCTIONS	COMPLETE ABOVE THEN O	K TO DOLID	
INSTRUCTIONS: COMPLETE ABOVE THEN OK TO POUR			
NEXT INSPECTION:			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			