



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-15-00027

OWNER'S NAME: DNR

DATE: 6/15/2015

TYPE: Footings

TIME STARTED: 9:08 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-24050-0001

1. Thickened Slab/Rebar OK.
2. Interior Bathroom Eliminated from Scope at Time of "Foundation Only" Review.
3. Interior Horizontal R-10 Rigid Insulation Not Installed per Drawing. Exterior Vertical Insulation Will Need to be Installed/Inspected Prior to Backfill.
4. Slab Plumbing for Future Restroom Not Installed at this Time.

INSTRUCTIONS: OK to Pour.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506