



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: FO-16-00017

OWNER'S NAME: PETTIT

DATE: 6/22/2016

TYPE: Footings

TIME STARTED: 10:22 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-12057-0007

1. Setbacks ok per CCR's
2. Garage monopour ok
3. House spread footings require rebar cages in wall per 31/D3 and 32/D3
4. All other spread footing and wall bar ok

**INSTRUCTIONS:** Complete above, Do Not Pour house foundation at this time.

**NEXT INSPECTION:** Re-inspect house

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506