



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: FO-16-00026

OWNER'S NAME: ANDES

DATE: 8/15/2016

TYPE: Footings

TIME STARTED: 10:27 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-34051-0008

1. (2) Spread Footings Missing. Bubbled in Red on Permit Set 'FO' Drawings.
2. Transverse Bars Missing on All 18" Footings.
3. Rear Footings (10' Walls) OK.
4. Side Footings (8' & 10' Walls) OK.
5. Setbacks OK.

INSTRUCTIONS: Make Corrections Call for Reinspect when Ready.

NEXT INSPECTION: Footings

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506