



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-16-00026

OWNER'S NAME: ANDES

DATE: 9/12/2016

TYPE: Slab plumbing

TIME STARTED: 12:28 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-34051-0008

1. Drawings not on site
2. Cannot confirm corrections
3. Cannot confirm slab insulation requirements
4. Underslab plumbing not on test

INSTRUCTIONS: Provide drawings/Place underslab plumbing on test/Confirm slab insulation requirements

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506