



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: 7/27/2026
Subject: AU-16-00008

Drinking Water	• Since there is already an existing well with one dwelling unit connected, an AWSO I/S is necessary for the project due to two dwelling units connecting to the well.
Wastewater	• If the existing septic system is going to be used for the new SFR a new connection permit application will need to be submitted with a design showing how the new SFR is going to connect to the existing septic. The homeowner or a licensed OSS designer can create the design. A final inspection of the connection will also be needed. • If the new SFR is NOT going to connect to the existing septic system, then a site evaluation followed by a design by a licensed OSS designer, or homeowner, will need to be submitted. A final inspection will be needed as well.

