



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: 2/05/2026
Subject: BL-26-00001

Drinking Water	<ul style="list-style-type: none">• No Comment
Wastewater	<ul style="list-style-type: none">• KCPHD recommends maintaining property line / easement setbacks of five feet from new and existing septic systems shown in WAC 246-272A-0210 Table IV• KCPHD recommends a Site Evaluation be conducted on lot B to verify soil type in regard to minimum land area requirements WAC 246-272A-0320 Table XI

