



*To Protect and Promote the Health and the Environment of the People of Kittitas County*

**To: All Staff**  
**From: Environmental Health**  
**Date: 03/23/2026**  
**Subject: BL-26-00002 Fowler Creek Trails**

<b>Drinking Water</b>	<ul style="list-style-type: none"><li>I spoke with Pat Deneen about the 2 wells on the Fowler Creek Trail map to get clarification. The well in between lots 87 and 88 serves the Granite Creek Water system and the well on lot 85 and 90 serves the house on lot 77. Therefore, this well must meet the set back of 50' from property lines as per 13.20.040 county code.</li></ul>
<b>Wastewater</b>	<ul style="list-style-type: none"><li>No permits were located for the septic system serving the house or associated parcels. All septic systems must meet required setbacks.</li></ul>

