



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: April 29, 2026
Subject: BL-26-00004 Central WA Land Group

Drinking Water	<ul style="list-style-type: none">• For any boundary lines in proximity to wells, please ensure that wells are not relocated within 50 feet of property lines
Wastewater	<ul style="list-style-type: none">• Please confirm that all septic systems are located at or beyond the minimum proposed setback distances from property lines, and that any abandoned septic systems will be appropriately decommissioned by filling or removal

