



To Protect and Promote the Health and the Environment of the People of Kittitas County

November 28, 2023

Chace Pedersen, Planner I
Community Development Services
411 N. Ruby Street
Ellensburg, WA. 98926

Dear Chace,

The following comments are the Environmental Public Health comments on the CU-23-00002 The Outpost, Notice of Application. The applicant requested a well site inspection of the existing well on September 5, 2023. The inspection was done October 3, 2023. There were several mitigating measures that were required to be done to enable the current well site to be utilized as a public water source. The water system serving the proposed project will be required to be approved as a Group A-transient, non-community water system by the Washington State Department of Health, (WAC 246-290).

Future use will generate greater than 3500 gallons of sewage per day and will be classified as a large on-site sewage system (LOSS). The applicant has stated they are working with a consultant to install a LOSS.

Thank you for this opportunity to comment,

Sincerely,

A handwritten signature in cursive script, appearing to read "Holly Erdman".

Holly Erdman, B.S.
Environmental Health Specialist II



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926

T: 509.962.7515 · F: 509.962.7581

www.co.kittitas.wa.us/health/