



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: April 22, 2026
Subject: CU-26-00001 Jentges

Drinking Water	<ul style="list-style-type: none">Proposed activities classify this project as a Group water system. Because the source is not limited to a single-family dwelling, requirements include mandated water testing, a 100-foot sanitary control area, and formal state approval and inspection. Please reach out to Kittitas County Public Health for additional guidance. This well may need to be relocated into another area to obtain the necessary setbacks.
Wastewater	<ul style="list-style-type: none">A review of the original septic design may be necessary to ensure it is sufficient for the proposed project and proposed amount of people it may serve. Please contact KCPHD with any questions regarding these requirements.

