



To Protect and Promote the Health and the Environment of the People of Kittitas County

December 20th, 2024

Thorp Landing Water System
Joel Greer, Owner
1401 W. Dolarway Rd, Ste 301
Ellensburg, WA 98926

RE: Approval of Thorp Landing Water System Well #2

Mr. Greer,

The Group B Water System application and information package for the above referenced project received in the office has been reviewed and in accordance with the provisions of WAC 246-291, is hereby FULLY APPROVED by Kittitas County Public Health Department.

Approval of this water system has been conditioned upon the agreement that management of ownership of the water system is being provided by said Satellite Management Agency.

Our approval of your Group B Public Water system design under Chapter 246-291 WAC does not confer or guarantee any right to withdraw or divert ground water. Contact our local planning department or the Washington State Department of Ecology for more information about your legal rights to use groundwater. Our approved number of service connections is based on your representation of available water quantity and may be reduced commensurate with your actual legal right to withdraw groundwater.

A water facilities inventory form has been completed and we have requested that the Washington State Department of Health Assign this system an identification number. This number must be used on all future water samples to ensure proper credit toward your sampling requirements. At least one coliform drinking water sample every twelve months, and one nitrate sample every thirty-six months is required to be submitted to a certified laboratory.

Regards,

A handwritten signature in black ink, appearing to read "M. Schumaier", is written over the printed name.

Melissa Schumaier, BS, REHS/R.S. Environmental Health Specialist II
Kittitas County Public Health Department

Cc: Washington State Department of Health