



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: March 31, 2025
Subject: LPF-25-00002

Drinking Water	<ul style="list-style-type: none">• The group B workbook was approved 1/31/2025, but a final inspection of the water system has not been completed, and the water system ID has not been issued by DOH office of drinking water.<ul style="list-style-type: none">○ In lieu of completing the Group B water system, the applicants may choose to follow the bonding requirements in KCC 13.30.080.• A 4-hour draw down test consistent with KCC 13.03.070, passing water quality tests for bacteria (within 1 year) and nitrate (within 3 years) must be submitted to KCPHD for the individual well #APE751.
Wastewater	<ul style="list-style-type: none">• Soil logs were evaluated and found to be adequate on 10/13/2011.

