



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: May 14, 2025
Subject: SP-25-00006

Drinking Water	<ul style="list-style-type: none">• A subdivision with nonpublic wells must provide a 100-foot water supply protection zone for each existing and proposed well. This protection zone must fit within the lot lines, or a copy of a restrictive covenant must be provided to each property located partially or entirely within the protection zone.
Wastewater	<ul style="list-style-type: none">• The houses each have their own permitted 3-bedroom septic system. No requirements for wastewater.

