



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: 8/18/2026
Subject: SP-26-00007 Shultz

Drinking Water	• New wells proposed on the parcels will need to complete and submit a well site review application for approval of well site. • A water supply protection zone of 100ft radius for each existing or proposed well site for the parcels per WAC 246-272A-0320 (iii) • An AWSI I/S application is necessary for each proposed lot. AWSI I/S must have: Well log no older than 10yrs old or 4hr flow test, a current well water quality test which includes a passing bacteriological (within 1 year) and nitrate (within 3 years) result, recorded proof of mitigation and metering agreement, and site plan. • For any lot that intends to share a well a AWSI I/S application is necessary. The AWSI I/S must have the same documents as an individual well but includes a recorded well-shared users' agreement and if the 100-foot well protection zone overlaps with the adjoining parcel, include the site plan or as-built for the adjoining parcel.
Wastewater	• Soil logs must be completed for each proposed lot.

