



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: March 16, 2026
SUBJECT: VA-26-00003 Swanson

ACCESS	<ol style="list-style-type: none"> 1. Issued Access Permit AA-25-00082. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering existing access. 2. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses. <p>In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application. (RC)</p>
ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CBP)
SURVEY	There are no survey comments regarding this application. (JT)
TRANSPORTATION CONCURRENCY	No transportation concurrency management application is required for this project as described.
FLOOD	No comments. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No comments. (RC)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.