



## KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Fire Marshal (509) 962-7000 Deputy Fire Marshal (509) 962-7657



---

February 26, 2025

Fire Marshal comments  
Mastec Communications  
Case Number ACU-25-00001

Zach Torrance-Smith, Project Planner

This application was reviewed by Dan Young in the Fire Marshal's Office. Dan can be reached at (509) 962-7000 or e-mail at [dan.young@co.kittitas.wa.us](mailto:dan.young@co.kittitas.wa.us). Where there are difficulties in meeting these conditions or if additional information is required, contact Dan in the Fire Marshal's office immediately.

Building construction occurring subsequent to this application shall be in accordance with the provisions of the county's building and fire codes. Additional specific requirements may be made at the time of building construction as a result of the permit review and approval process.

No gate may be installed across a required fire department access road or driveway without first obtaining a permit from the fire marshal's office. Inspection and testing of the gate will be required.

All commercial properties within Kittitas County must be equipped with a Knoxbox access system for emergency services.

If a new generator is to be installed it will require review and permitting through the fire marshal's office. A final inspection will be required.

Dan Young  
Fire Marshal

These comments are based on the information provided with the pre-application materials. Any revision to the proposal may change the Fire Marshal comments.