



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: March 5, 2025
SUBJECT: ACU-25-00001 Mastec Communications

ACCESS	<ol style="list-style-type: none">1. An approved access permit for access shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access. A new access would require a Road Variance.2. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.3. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application. (JS)
ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
SURVEY	There are no survey comments regarding this application (JT).
TRANSPORTATION CONCURRENCY	A concurrency evaluation and determination shall be required for all development applications in which the proposed development is projected to have an impact upon the transportation corridor or intersection. Developments generating 41 or fewer daily trips are exempt from the TIA and concurrency evaluation requirements. (KAH)
FLOOD	No comments. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.