

From: [Brenda Larsen](#)
To: [Jeff Watson](#)
Subject: RE: SG-08-00032 Hundley
Date: Wednesday, July 21, 2010 10:27:47 AM

Jeff,

After conducting a review of the above named project, I have the following comments:

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Creation of any additional roads or access must comply with the International Fire Code, i.e. 20 foot wide, all weather surface, slope/grade not greater than 12%, etc.
- Creation of additional lots with future development will require fire flow, water storage tank, water supply system (hydrants), and all other systems as required by code.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Brenda Larsen
Kittitas County Fire Marshal
509-962-7000

From: Jeff Watson
Sent: Friday, July 16, 2010 12:23 PM
To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan
Subject: SG-08-00032 Hundley

[SG-08-00032 Hundley](#)

This is a revised old application.

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeff Watson
Planner I

Kittitas County Community Development
Services

411 N. Ruby Street, Suite 2
Ellensburg, WA 98926
jeff.watson@co.kittitas.wa.us
P: 509.933.8274
F: 509.962.7682



"Building Partnerships-Building Communities"

All e-mail sent to this address will be received by the Kittitas County e-mail system and may be subject to Public Disclosure under RCW Chapter 42.56 and is subject to archiving and review by someone other than the recipient.

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14