From: Rich Elliott
To: Dusty Pilkington
Cc: Joe Seemiller; John Sinclair
Subject: RE: BL-17-00003 GIbb
Date: Tuesday, February 07, 2017 1:29:57 PM

KVFR Input –

1. When a building permit is issued, access and turn arounds for any improvements/buildings will need to be compliant with current IFC – Appendix D.
2. Addressing for any structures will need to be clearly visible from the county road from both directions of travel.

From: Dusty Pilkington [mailto:dusty.pilkington@co.kittitas.wa.us]
Sent: Tuesday, February 07, 2017 12:57 PM
To: Kelly Bacon; Holly Duncan; Holly Myers; Josh Hink; Lucas Huck; Rich Elliott; lonnie_allphin@ksd403.org; Cascade Irrigation
Subject: BL-17-00003 GIbb

Kelly, Hollys, Josh, and other interested parties,

Could you please review this application and submit comments for the decision. Control Click on the hyperlink above (or go to the attachment tab in EDEN). Comment period for this application ends on **02/21/2017**

BL-17-00003 Gibb (County Departments)
BL-17-00003 Gibb (Outside County Network)

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926

(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14