



## KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

### MEMORANDUM

**TO:** All Staff  
**FROM:** Public Works Plan Review Team  
**DATE:** June 6, 2024  
**SUBJECT:** BL-24-00009 Trust for Public Lands

<b>ACCESS</b>	<ol style="list-style-type: none"><li>1. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access.</li><li>2. Lots that access easements or rights-of-way controlled by different agencies, such as State highways, Forest Service Roads, irrigation canals, or railroads will require separate access approvals from those agencies. A copy of the access approval shall be submitted to the County prior to issuance of the County's access permit or preliminary approval for any land use development application. The County cannot grant access to roads or easements it does not control (KCC 12.05.030(G)).</li><li>3. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.</li><li>4. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.</li><li>5. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.</li></ol>
<b>ENGINEERING</b>	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
<b>SURVEY</b>	As the application does not contain a survey map, comments are reserved until final. (JT)
<b>TRANSPORTATION CONCURRENCY</b>	No Comments.

<b>FLOOD</b>	A portion of the parcels in this boundary line adjustment are located within the 100-year floodplain and floodway. If possible, any future development should remain outside of the floodplain in order to reduce risk and avoid mandatory flood insurance purchase requirements. All activities within the floodplain must be permitted through the floodplain development permit process and follow the regulations within KCC 14.08. (SC)
<b>WATER MITIGATION/ METERING</b>	No comments. (SC)
<b>AIRPORT</b>	No Comments.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.