

Lindsey Ozbolt

From: Brenda Larsen
Sent: Wednesday, August 28, 2013 1:23 PM
To: Lindsey Ozbolt
Subject: RE: Steigleder CUP (Gibson Produce) turn around condition

Has it been five minutes already?!?! So Sorry...coming up!!

The modified language is as follows:

An approved fire apparatus turnaround is required. The turnaround shall meet the requirements of Appendix D of the International Fire Code, and the applicant shall submit a site plan showing the location and size of the turnaround prior to construction.

Brenda Larsen
Kittitas County Fire Marshal
509-962-7000

From: Lindsey Ozbolt
Sent: Wednesday, August 28, 2013 1:15 PM
To: Brenda Larsen
Subject: Steigleder CUP (Gibson Produce) turn around condition

Hi Brenda,

Friendly reminder for you to please send me your rewritten fire turn around condition for Gibson Produce/Steigleder CUP to meet the request of the BOCC. I need to get that added to the Resolution and over to the PA's office this afternoon.

Thank you.

Lindsey Ozbolt
Staff Planner

Kittitas County Community Development Services
411 North Ruby St., Suite 2
Ellensburg, WA 98926
Phone: 509-962-7637
Email: lindsey.ozbolt@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14