

Development Agreement Application Comments

To: Dusty Pilkington, Planning Official

From: Jesse Cox, Environmental Health Supervisor

Date: July 24, 2019

RE: DV-19-00001

Thank you for the opportunity to comment on the above mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Environmental Health requirements.

Findings

On Site Sewage

- Residential lots will be served by an On-site septic system.
- The RV complex will be served with a Large On-Site System designed to DOH standards with DOH oversight.
- Prior to any development on the steeper eastern slopes, a sewage disposal master plan shall be submitted to Kittitas County Environmental Health.

Water

- The applicant's plan for domestic water is to connect to the Easton Water District system for the future homes.

A Additional Information Required

No information is required for further review