



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: All Staff
From: Environmental Health
Date: May 29th, 2025
Subject: LP-25-00003

Drinking Water	<ul style="list-style-type: none"> Group B water system is proposed but this will limit any houses from having more than one water connection available (no ADU's or small houses with an additional water connection). Only one water connection will be allotted for each parcel. The state Department of Health office of drinking water advocates and encourages a singular water system rather than smaller systems like Group B systems. Public Health would strongly suggest they consider a Group A water system under this being one project (as defined under Department of Ecology) as stated in the original pre-app meeting. A well site review will be needed for either type of system
Wastewater	<ul style="list-style-type: none"> A site evaluation will be needed for each parcel to ensure soil type is suitable for a wastewater treatment system.
Food Safety	<ul style="list-style-type: none"> NA
Living Environment	<ul style="list-style-type: none"> NA





To Protect and Promote the Health and the Environment of the People of Kittitas County



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926

T: 509.962.7515 · F: 509.962.7581

www.co.kittitas.wa.us/health/