
, 			RECEI	VEDI
WATER WELL REPORT Original & I st copy – Ecology, 2 nd copy – owner, 3 nd copy – driller	CURRENT Notice of Intent No. W 176883		JUL 16	2015 LIAITY
Construction/Decommission ("x" in circle) 343 170	Unique Ecology Well ID Tag No. APT 347	1.000	CDS	OIALA
© Construction	Water Right Permit No			
Decommission ORIGINAL INSTALLATION Notice of Intent Number	Property Owner Name Teanaway Ridge	•		
	Well Street Address Big Creek	10		
PROPOSED USE:	City Cle Elum County Kittitas	B		
TYPE OF WORK: Owner's number of well (if more than one)	Location NW 1/4-1/4 NE 1/4 Scc 29 Twn20			
✓ New well ☐ Reconditioned 'Method : ☐ Dug ☐ Bored ☐ Driven ☐ Deepened ☐ Cable ✓ Rotary ☐ Jetted	(Lat/Long (s, t, r Lat Deg N 47 La Still REQUIRED)	t Min/Sec <u>1</u> 1		
DIMENSIONS: Diameter of well 6 inches, drilled 66 1/2 ft. Depth of completed well 66 1/2 ft.	Long Deg W 121 Lo	ng Min/Sec	06.970	
CONSTRUCTION DETAILS	Tax Parcel No. 20-14-29000-0006			
Casing Welded 6 "Diam: from +1 1/2 ft. to 65 ft. Installed: Liner installed "Diam: from ft. to ft.	5.1			
☐ Threaded "Diam. from ft. to ft.	CONSTRUCTION OR DECOMMISSION Formation: Describe by color, character, size of material and			
Perforations: No Type of perforation used	nature of the material in each stratum penetrated, with at least	one entry for eac		
SIZE of perfs in. by in. and no. of perfs from ft. to ft.	information. (USE ADDITIONAL SHEETS IF NECES MATERIAL	FROM	то	
Screens: Yes INo K-Pac Location	Brown, sandy clay	0	5	
Manufacturer's NameModel No	Brown clay, gravel		27	
Diam. Slot.size from ft. to ft.	Brown sand, gravel WB	27·	65	
Diam. Slot size from ft: to ft: Gravel/Filter packed: Yes No Size of gravel/sand Materials placed from ft.	Gray phylite	05	66 1/2	
Surface Seal: Yes No To what depth? 19 ft.				
Material used in seal Bentonite Did any strata contain unusable water?				
Type of water? Depth of strata				
Method of sealing strata off				
RUMP: Manufacturer's Name			•	
WATER LEVELS: Land-surface elevation above mean sea level 2067 ft.				
Static level 23 ft. below top of well Date 07-02-07				
Artesian pressure lbs. per square inch Date Artesian water is controlled by				
(cap, valve, etc.)				
WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? Yes Z No If yes, by whom?				
Yield: 'gal/min with ft drawdown after hrs.				
Yield: gal Imin with ft. drawdown after hrs. Yield: gal Imin with ft. drawdown after hrs.	•			
Recovery data (time:taken as zero when pump turned off) (water level measured from well top to water level)		-		
Time Water Level Time Water Level Time Water Level				
		RECEIV		
		LOCIA	ED	
Date of test gal /min. with ft_ drawdown after hrs.	J	UN 15 2	200	
Airtest 30 gal./min: with stem set at 63 ft. for 1 hrs.				
Artesian flow g.p.m. Date 07-02-07	. SERIMENT U	ECOLOGY = CENTRA	REGIONAL OFFICE	
Temperature of water Was a chemical analysis made?		ed Date 07-02		
WELL CONSTRUCTION CERTIFICATION: I constructed and/or acc Washington well construction standards. Materials used and the information				
☑ Driller ☐ Engineer ☐ Trainee Name (Print) Brett Phythian / Steven West				
Driller/Engineer/Trainee Signature	Address 9290 Hwy 2 / P.O.Box 777			
Driller or trainec License No. 1249	City, State, Zip Dryden / Leavenworth, WA 988	326		
If TRAINEE, Driller's Licensed No. Driller's Signature	Contractor's Registration No. TUMWADP 011 LZ	Date <u>07-03-2</u>	2007	
	 j			

P.O. Box 777 Leavenworth, WA 98826 Phone(509) 548-5361 Fax(509) 548-1100 343790



Pump Test Data Sheet

OWNER: Teanaway Ridge/Evergreen Utilities

PAGE 1 0F 1

WELL LOCATION:

DATE: 5-15-09

Big Creek Cle Elum, WA

OPERATOR: Scott Kruschke

MEASURING POINT IS: TOP OF CASING WHICH IS 1.5" ABOVE SURFACE

DEPTH OF WELL: 66:5'

CASING DIAMETER: 6"

DISCHARGE RATE GALLONS PER MINUTE: 60

WELL TAG #APT347

OL COLUTINE	I SUMBORD TIME	Toranio po Marcoland	0011 01111000	551445146
CLOCK TIME	ELAPSED TIME	STATIC DRAWDOWN		REMARKS
11:20	0	19.6'	65.	
11:25	. 5	35.7'.	65	
11:30	10	45.1'	65	
11:35	15	50.3'	62	VALVED BACK
11:40	20	50.5'	60	* * , *
11:45	25	50.5'	59.	VALVED BACI
11:50	30	50.5'	60	INCREASED
11:53	33	50.5'	60	
12:00	40	50.5'	60	STABILIZED
	PUMP OF	FSTART RECOVERY		
12:05	45	20.1'		
· · · · · · · · · · · · · · · · · · ·				
			•	