



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

M E M O R A N D U M

TO: All Staff
FROM: Public Works Plan Review Team
DATE: February 25, 2022
SUBJECT: SX-22-00005 Thorp Truss Rehab

Public Works has reviewed the Shoreline Exemption Application. Please see comments below:

If materials or equipment will be temporarily stored within the special flood hazard area, a floodplain development permit will be needed. Other project elements are minor activities consistent with Kittitas County Code Chapter 14.08 and therefore do not require a floodplain development permit, as they are occurring above the base flood elevation, do not constitute new obstructions to flow, and potential debris and waste will be contained and not enter the floodplain.